



NOTES:

1. COMPACT BASE AND SUB-BASE TO 100% STANDARD (ASTM D698) PER SECTION 02200, PART 3.01B OF CITY TECHNICAL SPECIFICATIONS.
2. CONCRETE IN THE ROW TO BE 5000PSI PER SECTION 03300, CHAPTER 3.2 AND REINFORCED WITH FIBERMESH OR STEEL PER SECTION 3300, CHAPTER 5 OF CITY TECHNICAL SPECIFICATIONS.
3. ALL LATERAL STREET CUTS MUST BE COVERED WITH STEEL PLATES OF SUFFICIENT THICKNESS TO SPAN THE CUT WITHOUT NOTICABLE DEFLECTION. PLATES TO REMAIN IN PLACE UNTIL THE CONCRETE HAS GAINED SUFFICIENT STRENGTH TO WITHSTAND TRAFFIC LOADS (24 HOUR MINIMUM).
4. ALL STREET PATCHES TO BE SQUARE OR RECTANGULAR WITH STRAIGHT, SAW CUT EDGES.

STANDARD CONSTRUCTION
DETAILS



CONCRETE PAVEMENT REPLACEMENT

PLATE NUMBER:

P08

APPROVED:

SIGNATURE ON FILE

CITY ENGINEER

SCALE: N.T.S.

DATED: FEBRUARY 2009