



12 INCH WIDE BY 4 INCH DEEP DRY MORTAR BED-CONTINUOUS (3000 PSI CONCRETE)

SECTION

PLAN

NOTES:

1. GRANITE CURBSTONE SHALL BE RECTANGULAR IN SHAPE, WITH A WIDTH OF 5 INCHES A DEPTH OF 16 INCHES, WITH A NOMINAL LENGTH OF 6 FEET. NO CURBSTONE SHALL BE LESS THAN 4 FEET OR GREATER THAN 8 FEET. WHEN THE BLOCKS ARE PLACED, THE MAXIMUM GAP BETWEEN THE BLOCKS SHOULD BE 1/8TH OF AN INCH. COMPACT BASE FOR NEW CURB 98% (ASTM D698).
2. AFTER THE GRANITE CURB IS SET TO LINE AND GRADE, THE WIDENED AREA SHALL BE INFILLED WITH 3000 PSI CONCRETE. THE CONCRETE SHALL BE PLACED TO A DEPTH OF 1 1/2 INCHES BELOW FINAL PAVEMENT GRADE OR TO FINISHED GUTTER GRADE.
3. AT EACH JOINT, 3000 PSI CONCRETE SHALL BE PLACED. THE CONCRETE SHALL BE PLACED APPROXIAMATELY 10 INCHES DEEP, 3 INCHES ON EITHER SIDE OF THE JOINT AND A THICKNESS OF 6 INCHES. CONCRETE SHALL NOT BE PLACED WITHIN 4 INCHES OF THE TOP OF THE GRANITE CURB.

STANDARD CONSTRUCTION DETAILS



GRANITE CURB DETAIL

PLATE NUMBER:

P10

APPROVED:

SIGNATURE ON FILE
CITY ENGINEER

SCALE: N.T.S.

DATED: FEBRUARY 2009