



NOTES:

1. THE TEE-WYE SHALL BE SET AT THE PROPER DEPTH TO ACCOMMODATE THE PROPOSED OR EXISTING HOUSE LATERAL.
2. CONNECT TRACER WIRE ON LATERAL TO TRACER WIRE ON MAIN WITH SPLICE CONNECTOR.
3. CONTRACTOR SHALL NOTIFY CITY OF SAVANNAH WASTEWATER CONVEYANCE DEPARTMENT (912-351-3834) 24 HOURS PRIOR TO CONNECTION TO EXISTING GRAVITY SEWER PIPE. ALL CONNECTIONS TO THE EXISTING GRAVITY SEWER PIPE MUST BE INSPECTED BY THE CONVEYANCE DEPARTMENT PRIOR TO BACK FILLING.

SANITARY SERVICE LATERAL CONNECTION

STANDARD
CONSTRUCTION
DETAILS



CITY OF
savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.

DATED: JAN 2017

PLATE NUMBER:

S3