



NOTES:

1. PIPE AND FITTINGS WITHIN CONCRETE ENCASEMENT SHALL BE WRAPPED WITH 6 MIL POLYETHYLENE PRIOR TO THE CONCRETE PLACEMENT.
2. ALL PIPE AND FITTINGS SHALL BE SDR 26 PVC.
3. THE CONNECTIONS TO AN EXISTING MANHOLE SHALL OCCUR BY CORE-DRILLING.
4. THE CONNECTIONS SHALL INCLUDE A WATERTIGHT BOOT (SEE DETAIL S12).

STANDARD DROP MANHOLE CONNECTION

**STANDARD
CONSTRUCTION
DETAILS**



CITY OF
savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.
DATED: JAN 2017
PLATE NUMBER:
S13