


NOTES:

1. PILE DEPTH SHALL BE CALCULATED BY THE ENGINEER BASED ON THE LOADING AND SOIL CONDITIONS.
2. A PIPE SUPPORT IS REQUIRED WITHIN 18" OF EACH ABOVE GROUND PIPE JOINT.
3. IF A BURIED JOINT IS WITHIN 5' OF THE TOE OF THE BANK, AN ADDITIONAL PIPE SUPPORT IS REQUIRED WITHIN 18" OF THE JOINT.

PIPE SUPPORT

STANDARD
CONSTRUCTION
DETAILS



CITY OF
savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.
DATED: JAN 2017
PLATE NUMBER:
S14