



NOTES:

1. ALL ENCLOSURE WIRE TO BE #16 AWG, COLOR BLUE, TYPE 1007
2. ALL FIELD WIRING SHALL BE DONE BY OTHERS
3. THIS LOOP DRAWING WILL WORK FOR DUPLEX, TRIPLEX, AND QUADRAPLEX SOFTSTART LIFTSTATIONS
4. \* INCLUDED AT CITY DISCRETION
5. AI MULTI INPUT 7 CAN BE FOR ANY OF THE FOLLOWING  
FORCE MAIN PRESSURE  
FLOW METER
6. RTU PURCHASE CONTACT INFORMATION:  
EMERSON WATER AUTOMATION SOLUTIONS  
200 BETA DRIVE PITTSBURGH, PA. 15238 (877)826-8514  
BOB BENDER 678-427-7418  
REF # CITY OF SAVANNAH MODEL: SVH2013



LIFT STATION-SCADA RTU CONTROLWAVE LOOP WIRING  
(DUPLEX,TRIPLEX,QUAD)

STANDARD  
CONSTRUCTION  
DETAILS



SCALE: N.T.S.  
DATED: JAN 2017  
PLATE NUMBER:  
**S21**