


NOTES:

19. EXTERNALLY MOUNTED DRY-TYPE TRANSFORMER. PROVIDE WITH WEATHERPROOF NEMA 3R ENCLOSURE.
20. AREA LIGHT PHOTO CONTROL MOUNTED ON CONTROL PANEL BACK-BOARD. AIM AWAY FROM ARTIFICIAL LIGHT SOURCES. PROVIDE TORK MODEL 2107 120/277V 600VA LED RATED DIE-CAST ZINC SPECIFICATION GRADE CONTROL.
21. LED FLOOD LIGHT: LUMARK NIGHT FALCON SERIES,CAT. NO. NFFLD-A25-E-UNV-66-S-CB WITH WOOD POLE FLOODLIGHT BRACKET; COOPER CAT. NO. 06469. MOUNT LIGHT 15' ABOVE FINISH GRADE, AIM TOWARDS WET WELL AND EQUIPMENT BACKBOARD.
22. PROVIDE A NO.6 (G) FROM EACH DISCONNECT SWITCH AND JUNCTION BOX TO THE PUMP CONTROL PANEL.
23. PROVIDE TWO 20A/1P SPARE BRANCH BREAKERS AND ONE 30A/2P SPARE BRANCH BREAKER.

LIFT STATION – ONE-LINE DIAGRAM

(CONTINUED ON S23A & S23B)

STANDARD
CONSTRUCTION
DETAILS



CITY OF
savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.

DATED: JAN 2017

PLATE NUMBER:

S23C